



SUBSURFACE DRAINAGE AT EDGE OF ROAD PAVEMENT

SCALE 1:10 @ A4

NOTES:

1. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE INDICATED.
2. SUBSURFACE DRAINAGE TO BE CLASS SN8 IN ACCORDANCE WITH AUSTRALIAN STANDARDS AS/NZS 2439:2007.
3. SUBSURFACE DRAINAGE TO BE LAID BELOW KERB, BACKFILLED WITH 'NO FINES' CONCRETE, IF EXISTING CONSTRAINTS PREVENT PLACEMENT BEHIND KERB AT COUNCIL ENGINEER'S DIRECTION.
4. SUBSURFACE DRAINAGE TO BE INSTALLED BELOW SERVICE CONDUITS.
5. SUBSURFACE DRAINAGE TO BE LAID AT A MINIMUM GRADE OF 1 in 200.
6. FLUSHOUT RISERS TO BE INSTALLED EVERY 120m IN ACCORDANCE WITH MAROONDAH CITY COUNCIL STANDARD DRAWING MCC-104, IF NO DRAINAGE PITS ARE AVAILABLE.



Maroondah
City Council

Engineering & Building Services
Ph: (03) 9298 4292
www.maroondah.vic.gov.au

Title:

SUBSURFACE DRAINAGE - AT EDGE OF ROAD PAVEMENT

Revision: 00

Date: October 2020

Sheet: 1 of 1

Standard Drawing Number:
MCC-103